

Emission Test Certificate

Friday 22nd November 2019

Supplier: The Laminex Group Technology Centre (22 Trewin Street, Wendouree, 3355, VIC)

Sample Description: LG Hausys HI-MACS Panel

Date Tested: November 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.2 - 13.1.2B & 13.2 Green Star Interiors V1.2 - 12.1.2B</p>	<p align="center">LG Hausys HI-MACS Panel</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.021 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V1911017