

Testing. Advising. Assuring.

EWFA CERTIFICATE OF TEST CERTIFICATE No.: SFC RTF180265.2 Page 1 of 1

Report Sponsor	Certificate Issue Date	Product Name
Laminex Group Pty Ltd 90-94 Tram Road Doncaster VIC 3108	26/02/2019	Decorated FR MDF

Test Report Reference	Referenced Standard	Report Re-Issue Date
EWFA 48506900.2	AS/ISO 9705- 2003 R2016 and AS5637.1-2015	26/02/2019

Introduction

The element of construction described below was tested by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for a complete description of the tested construction.

Description of Material and Performance

Tested Material – Decorated FR MDF panels constructed from wood fibre impregnated with resin and fire-retardant additive. The panels were factory bonded with melamine impregnated decorative paper on both sides. The panel tested had a 16mm FR MDF core with 80GSM decorative paper on each face, with a mass per unit area of 12.7kg/m².



Tested Performance

Group Number	2
SMOGR_{RC} (m²/s² x 1000)	16.4

Refer to the referenced test report for a complete description of the tested construction.

Conditions/Validity

- THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the construction, along with the validity statements, are given in the test report.
- The test report or regulatory information report does not provide an endorsement by Exova Warringtonfire Aus Pty Ltd of the performance of the actual products supplied.
- The results in this certificate relate to the configurations as detailed, and should not be applied to any other configuration. The results in this document assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- A full copy of the test report may be obtained from the sponsor.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	Unit 2, 409-411 Hammond Road, Dandenong, Victoria, 3175, Australia	
Phone	+61 (0)3 9767 1000	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By:  Muntaqim Pereira	Reviewed By:  A. Rosamilia