

Emission Test Certificate

Tuesday, July 29th, 2014

Supplier: The Laminex Group (22 Trewin St, Wendouree, VIC 3355)

Sample Description: Laminex Fire Retardant (FR) MDF

Date Tested: July 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center">Green Building Council of Australia</p> <p align="center">Green Star Office Interiors v1.1 IEQ-11</p>	<p align="center">Laminex Fire Retardant (FR) MDF</p>
<p align="center">Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.019mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140628