

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N. 43 006 014 106
1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O. Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

CLIENT : THE LAMINEX GROUP
PO BOX 720
WENDOUREE VIC 3355

TEST NUMBER : 7-587147-CV
ISSUE DATE : 21/09/2012
PRINT DATE : 21/09/2012

SAMPLE DESCRIPTION Clients Ref: "Sample 12287"
Product Name: White PVC foam sheet, Item 958385
Nom: PVC polymer foam sheet
Composition: 70% PVC, 10% Limestone, 5% Titanium Dioxide,
15% non-hazardous additions
Thickness: 16mm, Density 560 kg/m3

AS/NZS 1530.3-1999 Early Fire Hazard Guidance Test
MODIFIED NUMBER =====
OF SAMPLES TESTED

This test is for Guidance only
=====

A reduced number of specimens were tested to provide
guidance only as to the likely performance of the product
tested

	Specimen		
	1	2	
Ignitability index	13	11	Range 0-20
Spread of Flame Index	0	0	Range 0-10
Heat Evolved Index	3	1	Range 0-10
Smoke Developed Index	8	7	Range 0-10

The results only apply to the specimen mounted as
described in this report
Two specimens only were tested

Each test specimen was clamped in four places.

Specimens tended to flash before ignition. Ignition was based
on the occurrence of a single flash of flame which lasted
longer than 10 seconds.

196344

1

(END OF REPORT)

PAGE 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved

Samples, and their identifying descriptions have been provided by the client unless otherwise stated.
AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test
results relate only to the sample or samples tested. The above test results are designed to provide THE
CLIENT WITH GUIDANCE INFORMATION ONLY.

This document shall not be reproduced except in full and shall be rendered void if amended or altered.

This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the
content and format of the advertisement have been approved in advance by the Managing Director of
AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR

APPROVED SIGNATORY